

Attachment 2

Chemical Inventory

**ATTACHMENT 2
PLATFORM EUREKA
MISCELLANEOUS DISCHARGES
CHEMICAL INVENTORY
January 1, 2017 through March 31, 2017**

| <u>Fluid Type</u> | <u>Volume</u> (Monthly avg bbls per day) | <u>Product Name</u> | <u>Estimated Chemical Quantity</u> (Monthly avg gal per day) | <u>Average End-of-Pipe ¹ Concentration</u> (mg/l) |
|--|---|---------------------|---|---|
| 009 Non-contact Cooling Water (combined with excess seawater) | | | | |
| January | 68,571 | Chlorine | 0.86 | 0.3 |
| February | 68,571 | Chlorine | 0.86 | 0.3 |
| March | 68,571 | Chlorine | 0.86 | 0.3 |
| 008 Fire Control System Water | N / A | None | N / A | N / A |
| 013 Test Fluids | No Discharge | No Discharge | None | None |
| 017 Water Flooding Discharges | No Discharge | No Discharge | None | None |
| 021 Hydrotest Water | No Discharge | No Discharge | None | None |

¹ Chemical quantity for non-contact cooling water calculated with Operations monitoring results using a non-EPA chlorine test method (Hach DPD Color Wheel).

N / A: Not chlorinated.